

LOAD RESPONSE TOWARDS VOLTAGE IN TNB POWER SYSTEMS USING THE MEASUREMENT APPROACH

(Date received: 26.9.07)

Saad Mekhilef

Department of Electrical Engineering,
University of Malaya, 50603 UM, Kuala Lumpur
E-mail: saad@um.edu.my

ABSTRACT

This paper reports the load-voltage dependency using field measurements for a faulted condition that caused a momentary voltage sag in a Tenaga Nasional Berhad (National Power Utility) network in the Central Region. The static load model is used in this study and its suitability is discussed in comparison to the dynamic load model. A fast method of calculating real and reactive power based on available information is devised. The effect of voltage on real and reactive power is discussed at great length. Various factors influence the load characteristic, including weather, time of day, network conditions and type of feeder load. Long-term steady state data should be made available for analysis to back up results from this study. We can conclude that the location of the feeder from point of fault also plays an important role. Certain feeders exhibited more serious conditions compared to others during the fault.

Keywords: Load Dependency, Load Modeling, Load Response, Load Sensitivity, Measurement-Based Approach, Non-Linear Least Square Regression, Voltage Dip, Voltage Sag

1.0 INTRODUCTION

The global electric power demand is rapidly increasing. The increasing disparity between demand of energy and supply leads to a number of concerns in relation to the present and future availability of energy sources in the world, the environmental costs that will be associated to this growth, and how third world countries will handle the increasing energy needs of their growing populations [1]. The power industry depends more and more on the industry growth rate and the use of the existing capacity in the most effective way. Therefore current challenges in power engineering include optimising the use of the available resources and keeping high reliability for operating conditions that will include narrow stability and security margins [1].

Changes in the power generation and transmission systems, optimising the available resources while making environmental consideration, and ensuring high reliability in the system operation, are necessary in order to match the increasing demand in the load areas. The system planning must ensure controllable generation for regulating both frequency (by controlling the output of the active power) and voltage (by controlling the output of reactive power), and must control the costs and ability to operate as spinning reserves when needed. An optimisation and coordination of the available resources, as well as the construction of new generation plants will thus be necessary.

The fact that loads are generally voltage dependent is a critical aspect for the planning and operation of the power system. The load characteristic may result in a very optimistic or pessimistic design if it is not chosen appropriately, leading

the system to voltage collapse or on the other hand to very oversized security margins.

In the early stage of electric power system development, power quality issues were not addressed as a critical issue [11]. Today, it has become important due to more sensitive loads being connected to the electrical network. It becomes a major concern in Malaysia in view of the nation's transformation towards industrialisation in year 2020 [8].

The current scenario in Malaysia is that we assume a constant power sensitivity factor. This would mean that load does not change during a voltage deviation. This is a pessimistic approach to understanding the relationship between load and voltage. However, it is the safest method as the worst-case scenario is assumed. In order to optimize load, a better dependency factor needs to be tabulated. A recent study has been done in Malaysia using the polynomial static load model via the component-based approach [12]. CIBS Billing data was used to calculate the RCI (Residential, Commercial and Industrial) Index. Then, standard IEEE sensitivity factors were used to come up with the results. In order to take the study one step further, this research is aimed at calculating specific sensitivity factors instead of using default values in the process.

Section II of the paper explains the load modeling, and different approach to monitor the load substations to determine the sensitivity. Section III then presents the data used in this modeling. Section IV explains the non-linear regression is used when a best fit needs to be computed. Section V present the results obtained and Last, Section VI summarizes the conclusion presented in the paper.

2.0 LOAD MODELING

The interest in load modeling has been continuously increasing in the last years, and power system load has become a new research area in power systems stability. We now realize that load-voltage characteristics have a significant effect on system performance, and transient stability results are known to be highly dependent upon the load characteristics assumed [2]. Several studies have shown the critical effect of load

Two main approaches to load model development have been considered by the electric utility industry [3]. They are as follows:-

a. Measurement-Based Approach

The measurement-based approach involves placing monitors at various load substations to determine the sensitivity of load active and reactive power to voltage variations to be used directly, or to identify parameters for more detailed load models [2] [4]. This approach has the advantage of direct monitoring of the true load and can produce load model parameters directly in the form needed for power flow and transient stability program input. Its disadvantages include the cost of acquiring and installing the measurement equipment and the need to monitor all system loads or to extrapolate from limited measurements.

b. Component-Based Approach

The component-based approach involves building up the load model from information on its constituent parts. Three sets of data are required; load class data, load composition data and load characteristic data. Load class data describes a category of load such as residential, commercial or industrial. For load modeling purposes, loads are classed accordingly. Each class has a similar load composition and characteristics. Load composition data describes the fractional composition of the load by load components. This term can be applied to bus load or a specific load class. Load characteristic data is a set of parameters such as power factor, variation of active and reactive power with voltage, etc. It characterizes the behavior of a specific load. The component-based approach has the advantage of not requiring system measurements and therefore being more readily put into use. Since load characteristics and load composition data should not vary widely over a particular system, they can be developed once for the entire system. Only the load class mix data needs to be prepared for each bus or area and updated for changes in the system load [2].

A combination of both the measurement-based approach and the component-based approach is best to come to a conclusion on the inherent load characteristic.

The static load model has been used widely for the past many years, even to approximate dynamic components. It is not dependent on time and therefore it describes the relationship of the active and reactive power at any time with the voltage and/or frequency at the same instant of time.

The dynamic model has lately been employed by a number of utilities, especially regions with 4 seasons that use high amounts of heating loads at certain junctures of the year [1] [4][5]. It expresses this relationship at any instant of time, as a function of the voltage and/or frequency time history, including normally the present moment.

The 3 main load models explored in this research are as follows. These are the main load models that have been developed

and used in the recent past by various researchers throughout the world.

1. Polynomial Static Load Model

This is a branch of the static model that represents the power relationship to voltage magnitude as a polynomial equation, usually in the following form [3]:-

$$P = P_0 [a_1 (V/V_0)_2 + a_2 (V/V_0) + a_3] \quad [1]$$

$$Q = Q_0 [a_4 (V/V_0)_2 + a_5 (V/V_0) + a_6] \quad [2]$$

The parameters of this model are the coefficients (a_1 to a_6). This model is referred to as the ZIP model, since it consists of the sum of constant impedance (Z), constant current (I), and constant power (P) terms. The model has been implemented in [6].

2. Exponential Static Load Model

This is another branch of the static load model that represents the power relationship to voltage as an exponential non-linear equation, usually in the following form [3]:-

$$P = P_0 (V/V_0)^{np} \quad [3]$$

$$Q = Q_0 (V/V_0)^{nq} \quad [4]$$

The parameters of this model are the exponents, np and nq . By setting these exponents to 0, 1 or 2, the load can be represented by using constant power, constant current, or constant impedance models respectively. Other exponents can be used to represent the aggregate effect of different types of load components as expressed in [3][7].

3. Exponential Dynamic Load Model

Due to the large amount of electrical heating loads in 4-season countries, and its critical effect on voltage stability a load model with exponential recovery has been proposed [5]. The model is presented, as a set of non-linear equations, where real and reactive power has a non-linear dependency on voltage.

$$P_1 = P_r + P_0 \left[\frac{V}{V_0} \right]^{a_1} \quad [5]$$

$$T_p \frac{dP_r}{dt} + P_r = P_0 \left[\frac{V}{V_0} \right]^{a_2} - P_0 \left[\frac{V}{V_0} \right]^{a_1} \quad [6]$$

Here, V_0 and P_0 are the voltage and power consumption before a voltage change. P_r is the active power recovery, P_1 is the total active power response, T_p is the active load recovery time constant, a_1 is the transient active load-voltage dependence, and a_2 is the steady state active load-voltage dependence. Similar equations are also valid for reactive power.

For this research, the exponential static load model is used. This would be a natural progression since the constant power load model is currently implemented in TNB power systems. Based on previous works, the results obtained using the static model and dynamic model does not pose much differences if the amount of heating loads are minimal and the voltage deviation of the system is not too drastic [1].

3.0 DATA

The data obtained for this study is the voltage and current readings due to a fault that occurred on Saturday, 21st January 2006 at approximately 10.28am. The double phase to ground fault occurred at a 275kV overhead line (L2), which connects KL South (KULS) and Serdang (SRDG), both of which are major substations in the Central KL region. Weather during the incident was fine.

ION 7600 Power Quality Monitoring System (PQMS)

installed at various 33kv feeders in the Central Region recorded the RMS and sinusoidal voltage and current deviations during the fault event. This is the first time PQMS data is being used to evaluate load-voltage characteristics. Previously, data was only used to analyse voltage sag index for important customers in the region.

The fault incident affected 13 feeders. They are BJLL4L5, BTGA2L5, HCOM3L5, KLJT8L5, MERU4L5, NUNI13L5, PIDH2L5, PJST6L5, PMJU7L5, PROT3L5, SHAE8L5, SRDG1L5 and TMSY2L5.




Figure 1: Linear line during zero crossing

3.1 Determination of Phase Angle

Since data is sampled at standard 32 samples per cycle, a mathematical calculation of phase angle between voltage and current is devised based on the zero-crossing technique. Microsoft Excel is used.

The 2 successive points where the data changes from positive to negative for both phase voltage and current is of interest in the tabulation. The change indicates that the zero crossing occurs in between these 2 values. The actual value needs to be calculated. It is found that points close to zero crossing of the waveform form a linear line. Figure 1 illustrates the linear line observed when 6 data points of red phase sinusoidal voltage (VRpp) is plotted during zero crossing.

With this, the value of the point that cuts through zero can be accurately calculated via mathematical formulation using the fundamentals of linear line equations. The slope of the line is a constant value, thus we can use the following equation:-

$$(V - 0) / (V - V_1) = Vz \quad [7]$$

where,

V = last positive point of VRpp

V₁ = first negative point of VRpp

Vz = VRpp data point at zero crossing

The similar principal is used for phase current. The equation is as follows:-

$$(I - 0) / (I - I_1) = Iz \quad [8]$$

where,

I = last positive point of IRpp

I₁ = first negative point of IRpp

Iz = IRpp data point at zero crossing

VRpp	IRpp	phi	
11923.01	200.9945		
7173.327	154.372		
2228.448	99.9792	1.424148607	V _{zstep}
-3025.485	35.22583	2.515151515	I _{zstep}
-8311.95	-33.15372	1.091002908	Δ
-13403.22	-97.90709	12.27378272	θ
-17925.18	-160.0703	0.21421792	rad
-21796.5	-211.355	0.97714295	cos(rad)
-24512.93	-253.8332	0.21258329	sin(rad)
-26188.33	-288.023		

Figure 2: Example of excel computation of phase angle

The difference between space units of $VRpp$ and $IRpp$ can be computed. A step approach is implemented for ease of Excel calculation. Referring to Figure 2, since voltage is leading current in this case, $VRpp$ is treated as the first unit. It can be seen that $IRpp$ is 2 steps behind $VRpp$. Thus the formula is as follows:-

$$Vzstep = Vz + 1 \quad [9]$$

$$Izstep = Iz + (\text{no. of cells away from } Vz)$$

However, in the event that current leads voltage, $IRpp$ is treated as the first unit and the following equation applies:-

$$Izstep = Iz + 1 \quad [10]$$

$$Vzstep = Vz + (\text{no. of cells away from } Iz)$$

The difference between the cells is established. In this case current is always used as the reference point no matter whether it leads or lags voltage. The equation is as follows:-

$$\Delta = Izstep - Vzstep \quad [11]$$

Now, Δ has to be changed from units to degrees. Since the sampling rate is 32 samples per cycle, the following equation is used:-

$$\theta = (\Delta / 32) * 360^\circ \quad [12]$$

Since Excel only recognises radians and not degrees in its mathematical formulation, the next step is to convert as follows:-

$$\text{rad} = \theta * (\pi / 180^\circ) \quad [13]$$

Finally, the sine and cosine of the phase angle in radians is ready to be computed. By copying all these formulas in respective columns, the varying phase angle can be tabulated easily. The formulation of Real and Reactive Power proves to be an easy task as all the relevant information is available. The following equations are used:-

$$\text{Real Power, } P = V_{rms} * I_{rms} * \cos(\text{rad}) \quad [14]$$

$$\text{Reactive Power, } Q = V_{rms} * I_{rms} * \sin(\text{rad})$$

4.0 NON-LINEAR LEAST SQUARE REGRESSION

Non-linear regression is used when a best fit needs to be computed to a set of data with an inherent non-linear equation attached to it. The main difference between linear and non-linear regression is that the solution must proceed in an iterative fashion.

Looking at the static load model, it can be linearised by taking its base-10 logarithm to give the following equation:-

$$\text{Log } (P / P_0) = np \text{ Log } (V / V_0) + c \quad [15]$$

$$\text{Log } (Q / Q_0) = nq \text{ Log } (V / V_0) + c$$

In their transformed forms, these models can use linear regression to evaluate the constant coefficients. They could then be transformed back to their original state and used for predictive purposes. This has been done in previous works [3][5]. The problem is that the transformation distorts the experimental error. Linear regression assumes that the scatter of points around the line follows a Gaussian distribution and that the standard deviation is the same at every value of V . These assumptions are rarely true after transforming data. Furthermore, some transformations alter the relationship between V and P . Thus, non-linear regression is employed.

To remove the subjectivity of the chosen method, some criterion must be devised to establish a basis for the fit.

a. Residual Analysis

The residuals from a fitted model are defined as the differences between the response data and the fit to the response data at each predictor value.

$$r_i = y_i - \hat{y}_i \quad [16]$$

Assuming the model fitted to the data is correct, the residuals approximate the random errors. Therefore, if the residuals appear to behave randomly, it suggests that the model fits the data well. However, if the residuals display a systematic pattern, it is a clear sign that the model fits the data poorly.

b. Sum of Squares Due to Error (SSE)

This statistic measures the total deviation of the response values from the fit to the response values.

$$SSE = \sum_{i=1}^n (y_i - \hat{y}_i)^2 \quad [17]$$

A value closer to 0 indicates that the model has a smaller random error component, and that the fit will be more useful for prediction.

c. R-Square

This statistic measures how successful the fit is in explaining the variation of the data. Thus, R -square is the square of the correlation between the response values and the predicted response values. R -square is defined as the ratio of the sum of squares of the regression (SSR) and the total sum of squares (SST). SSR is defined as,

$$SSR = \sum_{i=1}^n (y_i - \bar{y})^2 \quad [18]$$

SST is called the sum of squares about the mean, and is defined as,

$$SST = \sum_{i=1}^n (y_i - \bar{y})^2 \quad [19]$$

where,
 $SST = SSR + SSE$

Given these definitions, R -square is expressed as,

$$R\text{-Square} = SSR/SST = 1 - (SSE/SST) \quad [20]$$

R -square can take on any value between 0 and 1, with a value closer to 1 indicating that a greater proportion of variance is accounted for by the model.

In this study, MATLAB software is used to perform the non-linear regression analysis.

5.0 RESULTS

Results are obtained for the following points of interest:-

- Voltage Profile Analysis
- Current Profile Analysis
- $P(\text{pu})$, $Q(\text{pu})$ and $V(\text{pu})$ Vs. Time Analysis
- $P(\text{pu})$ and $Q(\text{pu})$ Vs. Voltage Analysis
- Load Change Post Fault with respect to Voltage Sag
- Load Change During Fault with respect to Voltage Sag

Voltage is seen to gradually recover at all feeders. The full recovery of voltage is delayed due to re-connection of tripped load [1]. Voltage sag behavior of each phase is also clearly explained by the PSCAD Simulation performed. Voltage sags are seen to be longer for feeders closer to the fault point.

Current profile observations indicate that red phase current increase across all feeders during the fault. This could be caused by the nature of the fault. The Y-B-N fault on the HV side caused

the yellow and blue phase current to drop to zero, leaving the red phase to supply the 132/33kV transformer for all 3 phases. This would lead to temporary increase in current on red phase during the fault. The surge in current before stabilising at all phases for each feeder indicated a large percentage of motor load [7, 8, 9]. This would also account for the rise in red phase real power during the fault.

The active and reactive power for all phases and feeders is also seen to rapidly increase for a short instance of time after fault clearing to levels even above the pre-disturbance value. Surge of power is particularly overwhelming in terms of reactive power. This could be due to the reacceleration of motors, which requires high starting currents.

Upon voltage recovery, it is seen that certain feeders observed loads that are slightly higher than its pre-disturbance values. This type of load behavior has been observed for air conditioning load in previous studies [10]. A higher reactive load post-disturbance indicates that more reactive power is required to boost the supply following the voltage sag, as observed in many feeders. Most feeders showed a slightly higher operating voltage and lower real power readings post-disturbance. This is indicative that certain loads have failed to recover, boosting the voltage automatically.

Recovery time of the voltage increases as the severity increases. Load recovery time to point of stabilisation which shows mixed results in this research, indicates that more sensitive load takes a much longer time to recover. Based on information from TNB Regional Control Centre in Table 1, it can be seen that heavy industrial loads with more motors take a much longer time to recover.

Table 1: Load information for individual feeders

Feeder	Load Information
BJLL4L5	PPU Taman Teknologi (Astro, Tmn. Teknologi, Mimos, KOMDAQ)
BTGA2L5	SSU Chung Hwa (Plastic Factory)
HCOM3L5	PPU Hicom E (Metal Stamping, Teck See Plastic, Kohno Plastic, Federal Paper)
KLJT8L5	SSU Permodalan Nasional Bhd. & PPU PNAL (Bukit Bintang Commercial Complexes)
MERU4L5	PPU Puncak Alam (Small Industrial Companies)
PIDH2L5	SSU M Food Factory
PJST6L5	PPU Dunlop (Dunlop, Bousted Switching)
PMJU7L5	SSU Texas Instruments (Electronic Manufacturing)
PROT3L5	SSU Nissan IOI (Car Manufacturing)
SHAE8L5	SSU Nippon Electric Glass Factory No.2
SRDG1L5	PPU Perindustrian Bukit Serdang

Tables 2, 3 and 4 indicate results for load-voltage dependency based on post fault load change.

Table 2 : Load change post fault with respect to voltage sag for red phase

RED PHASE		
Feeder	$dp(\text{pre-post})/dv(\text{fault})$	$dq(\text{pre-post})/dv(\text{fault})$
BJLL4L5	0.778	1.926
BTGA2L5	0.444	0.333
HCOM3L5	0.370	0.444
KLJT8L5	0.084	-0.335
MERU4L5	-0.179	-0.893
NUNI13L5	0.082	-0.164
PIDH2L5	0.105	-1.263
PJST6L5	0.433	0.767
PMJU7L5	0.393	-0.429
PROT3L5	2.630	-4.889
SHAE8L5	0.185	0.519
SRDG1L5	0.167	-0.333
TMSY2L5	0.267	-1.367

Table 3 : Load change post fault with respect to voltage sag for yellow phase

YELLOW PHASE		
Feeder	$dp(\text{pre-post})/dv(\text{fault})$	$dq(\text{pre-post})/dv(\text{fault})$
BJLL4L5	1.080	2.160
BTGA2L5	0.708	1.083
HCOM3L5	0.667	0.667
KLJT8L5	0.087	-0.174
MERU4L5	0.056	-0.500
NUNI13L5	0.435	0.174
PIDH2L5	0.433	-0.577
PJST6L5	0.846	0.962
PMJU7L5	0.760	-0.320
PROT3L5	3.217	-6.696
SHAE8L5	0.458	0.167
SRDG1L5	0.080	-0.600
TMSY2L5	0.538	-1.500

Table 4 : Load change post fault with respect to voltage sag for blue phase

BLUE PHASE		
Feeder	dp(pre-post)/dv(fault)	dq(pre-post)/dv(fault)
BJLL4L5	0.322	0.831
BTGA2L5	0.241	0.741
HCOM3L5	0.224	0.414
KLJT8L5	-0.018	-0.073
MERU4L5	-0.027	-0.109
NUNI13L5	0.109	0.273
PIDH2L5	0.067	0.044
PJST6L5	0.233	0.616
PMJU7L5	0.225	0.085
PROT3L5	1.259	-2.759
SHAE8L5	0.169	0.288
SRDG1L5	-0.026	-0.132
TMSY2L5	0.183	-0.085

The load change post fault compared to voltage sag indicates that KLJT is least dependent to voltage. This could be because the fault occurred on a Saturday morning where many of the offices were not operating. Since KLJT is mainly made up of commercial load, the effect would have been severe if the fault were to occur on a weekday during working hours. BJLL and PROT showed highest dependency since both a technology based industries which would have been operating as usual on a Saturday morning.

Figures 5, 6 and 7 indicate results from MATLAB simulation to analyse load-voltage dependency during fault.

Table 5 : Load change during fault with respect to voltage sag for red phase using MATLAB simulation

RED PHASE						
Feeder	dp/dv	R ²	SSE	dq/dv	R ²	SSE
BJLL4L5	-2.583	0.7164	0.622	9.467	0.5622	20.38
BTGA2L5	-2.026	0.7567	0.2777	7.293	0.2477	19.84
HCOM3L5	-2.186	0.7914	0.2421	8.124	0.6164	10.57
KLJT8L5	-1.142	0.8508	0.1655	2.665	0.8836	0.5799
MERU4L5	-1.729	0.7773	0.2672	16.37	0.6918	10.64
NUNI13L5	-3.048	0.8993	0.4442	7.031	0.6384	10.82
PIDH2L5	-3.997	0.8544	0.7715	13.38	0.5232	24.77
PJST6L5	-3.370	0.7903	0.8616	9.373	0.2277	64
PMJU7L5	-2.064	0.7863	0.2274	3.330	0.7709	2.753
PROT3L5	-2.548	0.7199	0.6602	4.286	0.6767	0.5003
SHAE8L5	-0.9069	0.7061	0.1221	5.375	0.6285	4.262
SRDG1L5	-1.536	0.8170	0.2812	5.077	0.7070	5.284
TMSY2L5	-1.948	0.8098	0.5228	13.39	0.3345	46.61

Table 6 : Load change during fault with respect to voltage sag for yellow phase using MATLAB simulation

YELLOW PHASE						
Feeder	dp/dv	R ²	SSE	dq/dv	R ²	SSE
BJLL4L5	4.872	0.8979	0.1687	20.22	0.6286	59.27
BTGA2L5	6.085	0.9413	0.1391	6.097	0.9448	0.1392
HCOM3L5	6.797	0.9112	0.2566	6.646	0.9201	0.247
KLJT8L5	4.879	0.8831	0.2776	4.381	0.8991	0.1247
MERU4L5	7.320	0.9560	0.179	3.002	0.3439	3.384
NUNI13L5	5.143	0.9374	0.1123	5.097	0.9374	0.1102
PIDH2L5	10.200	0.8420	1.001	8.619	0.9305	0.2455
PJST6L5	3.827	0.9017	0.108	4.484	0.9004	0.2069
PMJU7L5	5.876	0.8723	0.3231	6.125	0.8936	0.3413
PROT3L5	4.593	0.9767	0.0349	5.818	0.7209	13.39
SHAE8L5	3.609	0.9595	0.04187	3.621	0.9624	0.04688
SRDG1L5	4.408	0.8883	0.1637	4.498	0.8945	0.1723
TMSY2L5	4.785	0.9345	0.09851	4.785	0.9345	0.09726

Table 7 : Load change during fault with respect to voltage sag for blue phase using MATLAB simulation

BLUE PHASE						
Feeder	dp/dv	R ²	SSE	dq/dv	R ²	SSE
BJLL4L5	1.690	0.7229	5.677	4.295	0.4705	62.42
BTGA2L5	2.162	0.6105	7.117	5.517	0.5928	187.3
HCOM3L5	2.201	0.6307	6.131	6.508	0.5586	78.03
KLJT8L5	2.996	0.9553	0.01122	2.996	0.9553	0.01125
MERU4L5	2.128	0.8989	0.0171	13.450	0.6006	87.11
NUNI13L5	2.183	0.5992	6.805	7.850	0.4840	66.94
PIDH2L5	2.165	0.4135	14.46	10.370	0.6058	171.7
PJST6L5	1.743	0.6242	10.33	3.944	0.5007	89.07
PMJU7L5	1.338	0.6311	0.04208	4.830	0.5050	45.5
PROT3L5	1.411	0.5417	8.982	2.507	0.6681	72.98
SHAE8L5	1.402	0.8793	0.009415	7.456	0.5129	47.54
SRDG1L5	1.401	0.8373	0.01824	3.256	0.3356	37.96
TMSY2L5	1.894	0.7191	5.424	3.846	0.3611	57.91

It is seen that load change during fault compared to voltage sag also indicates the same reasoning. It is seen that industries, namely factory based loads showed higher sensitivity compared to commercial based loads.

MATLAB modeling clearly indicated that real power was more accurately computed compared to reactive power. It is also seen that the severity of the disturbances accentuates the nonlinear behavior of the load. This is noticed at the blue phase especially. Thus, accuracy of the simulation was indeed questionable for larger voltage sags. It is also seen that general linear calculations as done previously [4] shows values that are much less sensitive compared to the actual situation.

6.0 CONCLUSION

An identification procedure to estimate load dependency to voltage is investigated. The non-linear Least Squares Regression method is finally chosen and implemented using MATLAB. Since, varying phase angle values were not directly measured, a method was devised to calculate these values, which were needed to calculate real and reactive power. It is found that all feeders in question supply heavy commercial and industrial loads.

The surge in current, real and reactive power before stabilising to post-disturbance values, indicate motor and air conditioning loads are involved. Through comparative analysis and plotting of graphs, it can be seen that the larger the voltage sag for a particular phase of a feeder, the slower the recovery time. However, when comparing between feeders, the inherent nature or type of the load connected dictates how fast the recovery takes. The nature of the load at the particular time of the fault also dictates the value of the post disturbance voltage and power.

Analysis also indicates that the larger the voltage sag, the non-linear behavior of the load accentuates. This explains the MATLAB statistical analysis for blue phase reactive power results in particular. Thus, the static load model can only be used

for small voltage variations of sensitive feeder loads. A proper comparison between feeders can only be justified with better information on various aspects of the feeder including daily load demand profile, seasonal load variations and customer habits through out a long term period.

Location of the feeder from point of fault also plays an important role. Certain feeders exhibited more serious conditions compared to others during the fault. Load at KLJT is seen to have been least affected by voltage, while BJLL and PROT seem to be most affected by voltage.

For future work, steady state data should be made available to analyse the load response to voltage during small voltage variations. Data should be taken for various parts of each day, each week for a one-year period to see the effect of weather and time difference on load. High and low peak demand; determination of daily, weekly and seasonal load patterns based on weather conditions and customer habits in the area should be analysed for a long term period. This would mean more rigorous metering and data collection than presently available. Dynamic load modeling should be tested out for faults with large voltage sags. ■

REFERENCES

- [1] Ines Romero Navarro, "Dynamic Power System Load: Estimation of Parameters from Operational Data", Lund University, Sweden, 2005
- [2] William W. Price, Kim A. Wirgau, Alexander Murdoch, James V. Mitsche, Ebrahim Vaahedi and Moe A. El-Kady, "Load Modeling for Power Flow and Transient Stability Computer Studies", IEEE Transactions on Power Systems, Vol.3, No.1, February 1988, pp 180 - 187
- [3] Carson W. Taylor, "Power System Voltage Stability", EPRI, McGraw Hill Inc.1994
- [4] Chia-Jen Lin, Yung-Tien Chen, Chiew-Yann Chiou, Chang-Horng Huang, Hsiao-Dong Chiang, Jin-Cheng Wang and Lazhar Feikh-Ahmed, "Dynamic Load Models in Power Systems Using the Measurement Approach", IEEE Transactions on Power Systems, Vol.8, No.1, February 1993, pp: 309 - 315
- [5] Daniel Karlsson and David J. Hill, "Modeling and Identification of Nonlinear Dynamic Loads in Power Systems", IEEE Transactions on Power Systems, Vol.9, No.1, February 1994, pp: 157 - 166
- [6] Alf Dwyer, Ron E. Nielsen, Joerg Stangl and Nokhum S. Markushevich, "Load to Voltage Dependency Tests at B.C. Hydro", IEEE Transactions on Power Systems, Vol.10, No.2, May 1995, pp: 709 - 715
- [7] I.A. Hiskens and J.V. Milanovic, "Load Modeling in Studies of Power System Damping", IEEE Transactions on Power Systems, Vol.10, No.4, November 1995, pp: 1781 - 1788
- [8] B. Sawir, M.R. Ghani, A.A. Zin, A.H. Yatim, H. Shaibon and K.L. Lo, "Voltage Sag: Malaysian's Experience", IEEE, 1998
- [9] K. Tomiyama, S. Ueoka, T. Takano, I. Iyoda, K. Matsuno, K. Temma and J. J. Paserba, "Modeling of Load During and After System Faults Based on Actual Field Data", IEEE Transactions on Power System, Volume 3, 13-17 July 2003
- [10] Emil Kermendey, Nervis Villalobos and Martin Schmiegl, "The Impact of Load Behaviour on Voltage Stability, an Application Case in ENELVEN/VENEZUELA"
- [11] Rosli Omar and Marizan Sulaiman, "Voltage Dips Simulation in Distribution Systems in Malacca Malaysia", International Conference on Energy, Environment and Disasters- INCEED2005, Charlotte, NC, USA, July 2005
- [12] Nor Azman Atib, "Analysis of Load Response to Frequency Deviations for TNB Power Systems", University Malaya, June 2005

PROFILE



ASSOCIATE PROF. DR SAAD MEKHILEF

He received the B. Eng. degree in Electrical Engineering from University of Setif in 1994, and Master of Engineering science and PhD from University of Malaya 1998 and 2003 respectively. He is currently a Associate Professor at Department of Electrical Engineering; University of Malaya. Dr Saad is the author and co-author of more than 90 publications in international journals and proceedings. He is actively involved in industrial consultancy, for major corporations in the power electronics projects. His research interests include industrial electronics, power conversion techniques, control of power converters, renewable energy and energy efficiency.